

“SWATCH BHARTH SWATCH HOSAKOTE”

OFFICE OF
CITY MUNICIPAL COUNCIL
HOSAKOTE, BANGALORE RURAL



Tel: 27931221,
Fax: 27931759
Email- itstaff_ulb_hosakote@yahoo.com
Web Site. www.hosakotecity.mrc.gov.in

No: CMC/HOS/Tec/178/2022-23

Dated: 27/02/2023


TO WHOM IT MAY CONCERN

PERFORMA FOR SAFE WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an Inspection team headed by Mr. Shiek Mohiuddin (AEE) from City Municipal Council, Hosakote inspected the Mahadeva International School Behind Nandashree Kalyana Mantapa, Doddagattiganabbe Road, Hosakote town, Bangalore Rural District on 28/02/2023 and found that the mahadeva International School has safe Drinking water facilities for the students and members of staff of the institution and is maintain the hygienic sanitation condition in the school building and the campus as per norms prescribed by the central/State/U.T. Govt.

The above is valid for a period of 28/02/2024

(Note: This is issued on the request Dated: 27/02/2023 from the applicant)


Municipal Commissioner
CMC, Hosakote.

To,

Sri Ramanatha. MM
The Secretary
Mahadeva International School
Behind Nandashree Kalyana Mantapa,
Doddagattiganabbe Road
Hosakote Town-562114
Bangalore Rural Dist.

TEST REPORT

Sample Code: TC506923000008118F	Date of Sampling	--
Name Of the Organization : M/s. THE SECRETARY Mahadeva International School, Behind Nandashree Kalyana Mantapa, Doddagattiganabbe Road, Hoskote Town, Bangalore - 562114.	Date of Receipt	27.02.2023
	Date of Analysis Started	27.02.2023
	Date of Analysis Completed	02.03.2023
	Date of Report	02.03.2023
	Environmental Condition	Ambient
Sample Particulars : R O Water	Sample Drawn By	Customer
Source of Collection : --	Report No	TC506923000008118F
Sampling Method : --	Condition of the Sample	Satisfactory

RESULTS

S. No	Parameters	Protocol	Results	Standards IS : 10500 - 2012	
				Desirable Limits	Permissible Limits
1	pH Value	IS 3025 (Part - 11) 2017	6.58	6.5-8.5	No Relaxation
2	Colour, Hazen Unit	IS 3025 (Part - 4) 2017	2.0	5.0 Max	15
3	Odour	IS 3025 (Part - 6) 2017	Agreeable	Agreeable	Agreeable
4	Turbidity, NTU	IS 3025 (Part - 10) 2017	0.1	1.0 Max	5.0 Max
5	Total Dissolved Solids, mg/L	IS 3025 (Part - 16) 2017	104.6	500 Max	2000 Max
6	Total Hardness as CaCO ₃ , mg/L	IS 3025 (Part - 21) 2019	32.0	200 Max	600 Max
7	Calcium as Ca, mg/L	IS 3025 (Part - 40) 2019	9.6	75 Max	200 Max
8	Magnesium as Mg, mg/L	IS 3025 (Part - 46) 2014	1.9	30 Max	100 Max
9	Alkalinity as CaCO ₃ , mg/L	IS 3025 (Part - 23) 2019	26.4	200 Max	600 Max
10	Chlorides as Cl, mg/L	IS 3025 (Part - 32) 2019	25.8	250 Max	1000 Max
11	Sulphates as SO ₄ , mg/L	IS 3025 (Part - 24) 2019	2.4	200 Max	400 Max
12	Nitrates as NO ₃ , mg/L	IS 3025 (Part - 34) 2019	0.7	45 Max	No Relaxation
13	Iron as Fe, mg/L	IS 3025 (Part - 53) 2019	0.06	1.0 Max	No Relaxation
14	Fluoride as F, mg/L	IS 3025 (Part - 60) 2019	0.1	1.0 Max	1.5
Microbiological Parameters					
15	E.coli/100ml	IS 15185 - 2016 (RA 2021)	Absent	Absent	Absent
16	Coliforms/100ml	IS 15185 - 2016 (RA 2021)	Absent	Absent	Absent

INFERENCE: As per IS Standards 10500 - 2012, The above tested results are within the limits.

Reddy Ramanamma
ANALYZED BY

Katha S
MICROBIOLOGIST



Vijaya Simha Reddy P.R.
AUTHORISED SIGNATORIES

VIJAYA SIMHA REDDY. P.R.
Technical Manager

End of the Report

Note:

1. The results refer only to the tested samples and applicable Parameters
2. This report not to be reproduced wholly or in part & Cannot be used as an evidence in the Court of Law
3. Samples will be stored for a period of 15 Days on receipt. Gaseous samples, Food samples and Microbiology samples will be discarded after analysis
4. Nexus Test Labs doesnot hold any responsibility for variation in test results for samples kept on hold for want of clarification

SHILPA
Sr. Microbiologist

NEXUS TEST LABS PVT. LTD.,

Sy.No-114, Site No: 115,116 1st & 2nd Floor, Rajapalya, Hoodi Gardens, Mahadevapura Post, Whitefield Road, Bangalore - 560 048
Tel : +91 8050448777, Email : info@nexustestlabs.com, Web : nexustestlabs.com



Certificate No. : TC 5069

1 of 1